


HOSPITAL INSPECTION CASE STUDY

Illegal Disposal

Disposal of Hazardous Waste alcohol into the sink drain in Microbiology Lab



HOSPITAL INSPECTION CASE STUDY

Improper Hazardous Waste Determination

Waste pharmaceuticals

Waste alcohols

Waste paint stripper

Methylene chloride


Uranyl nitrate



HOSPITAL INSPECTION CASE STUDY

Missed Weekly Inspections

Satellite Accumulation Containers



HOSPITAL INSPECTION CASE STUDY

Hazardous Waste Training

Emergency Coordinator and other personnel had not received Hazardous Waste training



HOSPITAL INSPECTION CASE STUDY

Incomplete Phone Postings

Had not posted the locations of emergency equipment including fire extinguishers and spill control equipment

Emergency Contacts Telephone Posting

Post this sheet near the telephone(s) in areas where hazardous waste is handled or stored.

Company Emergency Coordinator(s)

Name	Pager #	Work Phone	Home Phone
_____	_____	_____	_____
_____	_____	_____	_____

Fire Department Phone _____

Police Department Phone _____

Hospital Phone _____

Colorado 24-hour Emergency Response Line Phone 1-877-518-5608

National Response Center (24-hour) Phone 1-800-424-8802

Location of Emergency Response Equipment:

*Fire extinguishers _____

*Fire alarm (if present) _____

*Spill control material _____

*Special equipment (if present) _____

(Fulfills emergency contact telephone posting requirements for SQG's)

HOSPITAL INSPECTION CASE STUDY

Incompatible Storage

Incompatible waste Oxidizers (uranyl nitrate and silver nitrate) stored with waste Ignitables (Carbol Fuchsin) in Cytology Laboratory



HOSPITAL INSPECTION CASE STUDY

HAZARDOUS WASTE
(final determination by Chemical Waste Program)

NAME: Brian Brosnan

START DATE: 8/6/2009 PHONE # 626-XXXX

FILL DATE: 8/25/2009

CONTENTS:

Water 50%

Acetic Acid 20%

Formic Acid 30%

pH = 3.0

check all **HAZARDS** that apply

☐ Flammable (07, 08, 09) ☐ Poison (18)

☒ Acid (02) ☐ Base (01) ☐ Oxidizer (16, 12)

☐ Low Hazard (05, 06)



No Hazardous Waste Labels

Two satellite storage containers located in the Cytology Laboratory were not properly marked with the words "Hazardous Waste"

HOSPITAL INSPECTION CASE STUDY

Penalty

\$205,000

